

Detailed Test History



Test Status: All, Test Type: All
Person: All, Instrument: All
From: 01/01/2012 To: 24/04/2014

Client:	Site: LSL	Location: Test		
Asset ID: 0000000678	Description: XP5	User: RYAN	Test Instrument: 29D-0685	
Test Type	Date	Result	Unit	Status
Visual	09/11/2012			Pass
Earth Continuity	09/11/2012	0.068	ohm	Pass
Insulation Voltage	09/11/2012	250	V	Information
Insulation	09/11/2012	> 199	MOhm	Pass
Live - Neutral Voltage	09/11/2012	240	V	Information
Live Voltage	09/11/2012	237	V	Information
Neutral Voltage	09/11/2012	6	V	Information
Load Current	09/11/2012	< 0.50	A	Information
PE Conductor Current	09/11/2012	< 0.15	mA	Pass
Load Current	09/11/2012	< 0.50	A	Information
Touch Current	09/11/2012	< 0.07	mA	Pass

Overall: Pass

Asset ID: 00000047515	Description: LED BAR	User: RYAN	Test Instrument: 29D-0685	
Test Type	Date	Result	Unit	Status
Visual	13/12/2012			Pass
Earth Continuity	13/12/2012	0.06	ohm	Pass
Insulation Voltage	13/12/2012	250	V	Information
Insulation	13/12/2012	50	MOhm	Pass
Live - Neutral Voltage	13/12/2012	244	V	Information
Live Voltage	13/12/2012	238	V	Information
Neutral Voltage	13/12/2012	6	V	Information
Load Current	13/12/2012	< 0.50	A	Information
PE Conductor Current	13/12/2012	0.65	mA	Pass
Load Current	13/12/2012	< 0.50	A	Information
Touch Current	13/12/2012	< 0.07	mA	Pass

Overall: Pass

Asset ID: 00000047597	Description: PIONEER DJM 400	User: RYAN	Test Instrument: 29D-0685	
Test Type	Date	Result	Unit	Status
Visual	19/11/2012			Pass
Insulation Voltage	19/11/2012	250	V	Information
Insulation	19/11/2012	> 199	MOhm	Pass
Live - Neutral Voltage	19/11/2012	241	V	Information
Live Voltage	19/11/2012	235	V	Information
Neutral Voltage	19/11/2012	6	V	Information
Load Current	19/11/2012	< 0.50	A	Information
Touch Current	19/11/2012	< 0.07	mA	Pass

Overall: Pass

Asset ID: 00000047614	Description: RADIO MIC PSU	User: RYAN	Test Instrument: 29D-0685	
Test Type	Date	Result	Unit	Status
Visual	15/12/2012			Pass
Insulation Voltage	15/12/2012	250	V	Information
Insulation	15/12/2012	> 199	MOhm	Pass
Live - Neutral Voltage	15/12/2012	239	V	Information
Live Voltage	15/12/2012	233	V	Information
Neutral Voltage	15/12/2012	5	V	Information
Load Current	15/12/2012	< 0.50	A	Information
Touch Current	15/12/2012	< 0.07	mA	Pass

Overall: Pass

Asset ID: 00000047637	Description: PHANTOM 50 SPOT	User: RYAN	Test Instrument: 29D-0685	
Test Type	Date	Result	Unit	Status
Visual	16/02/2013			Pass
Earth Continuity	16/02/2013	0.072	ohm	Pass
Insulation Voltage	16/02/2013	250	V	Information
Insulation	16/02/2013	> 199	MOhm	Pass
Live - Neutral Voltage	16/02/2013	242	V	Information
Live Voltage	16/02/2013	238	V	Information
Neutral Voltage	16/02/2013	6	V	Information
Load Current	16/02/2013	< 0.50	A	Information
PE Conductor Current	16/02/2013	< 0.15	mA	Pass
Load Current	16/02/2013	< 0.50	A	Information
Touch Current	16/02/2013	< 0.07	mA	Pass

Overall: Pass

Detailed Test History



Test Status: All, Test Type: All
Person: All, Instrument: All
From: 01/01/2012 To: 24/04/2014

Asset ID: 00000047637 Description: PHANTOM 50 SPOT User: RYAN Test Instrument: 29D-0685

Test Type	Date	Result	Unit	Status
Visual	16/02/2013			Pass
Earth Continuity	16/02/2013	> 20.0	ohm	Fail
Overall: Fail				

Asset ID: 00000047637 Description: PHANTOM 50 SPOT User: RYAN Test Instrument: 29D-0685

Test Type	Date	Result	Unit	Status
Visual	16/02/2013			Pass
Earth Continuity	16/02/2013	6.344	ohm	Fail
Overall: Fail				

Asset ID: 00000047637 Description: PHANTOM 50 SPOT User: RYAN Test Instrument: 29D-0685

Test Type	Date	Result	Unit	Status
Visual	16/02/2013			Pass
Earth Continuity	16/02/2013	0.266	ohm	Fail
Overall: Fail				

Asset ID: 00000047637 Description: PHANTOM 50 SPOT User: RYAN Test Instrument: 29D-0685

Test Type	Date	Result	Unit	Status
Visual	16/02/2013			Pass
Earth Continuity	16/02/2013	> 20.0	ohm	Fail
Overall: Fail				

Total Tests: 9